

Division of Facilities Construction and Management

MULTI-STEP BIDDING PROCESS FOR CONTRACTORS

Request For Solicitation For Construction Services

Stage II – Electrical Contractors Bidders List

October 27, 2006

FIRE ALARM UPGRADE PROVO FOURTH DISTRICT COURT

ADMINISTRATIVE OFFICE OF THE COURTS PROVO, UTAH

DFCM Project No. 06107150

Protection Consultants Inc. 182 South 600 East, Suite #202 Salt Lake City, Utah 84102

TABLE OF CONTENTS

	Page #
Title Sheet	1
Table of Contents	2
Invitation to Bid	3
Stage II – Multi-Step Bidding Process	4
Stage II - Project Schedule	8
Bid Form	9
Bid Bond Form	11
Contractors Sublist Form	12
Fugitive Dust Plan	15
Contractor's Agreement	22
Performance Bond	27
Payment Bond	28
Change Order Form	29
Certificate of Substantial Completion	30

Current copies of the following documents are hereby made part of these contract documents by reference. These documents are available on the DFCM web site at http://dfcm.utah.gov or are available upon request from DFCM:

DFCM General Conditions dated May 25, 2005 DFCM Application and Certificate for Payment dated May 25, 2005

Technical Specifications & Drawings: Protection Consultants Inc.

The Agreement and General Conditions dated May 25, 2005 have been updated from versions that were formally adopted and in use prior to this date. The changes made to the General Conditions are identified in a document entitled Revisions to General Conditions that is available on DFCM's web site at http://dfcm.utah.gov

INVITATION TO BID

ONLY FIRMS PRE-QUALIFIED DURING STAGE I OF THE RFS ARE ALLOWED TO BID ON THIS PROJECT

The State of Utah - Division of Facilities Construction and Management (DFCM) is requesting bids for the construction of the following project:

FIRE ALARM UPGRADE – PROVO FOURTH DISTRICT COURT ADMINISTRATIVE OFFICE OF THE COURTS – PROVO, UTAH PROJECT NO: 06107150

Project Description: upgrade existing fire alarm system. Construction Cost Estimate: \$160,000.00.

FIRM NAME	POINT OF CONTACT	<u>PHONE</u>	<u>FAX</u>
Arco Electric	Paula Sorensen	(801) 566-1695	(801) 566-0927
Capital Electric	Mike Mora	(801) 908-6660	(801) 908-6667
Electro Specialist, Inc.	Gordon Banks	(801) 572-2998	(801) 572-5658
Hidden Peak Electric Co., Inc	Brian Bales	(801) 262-5513	(801) 262-5689
Power Electric Company	Tina Sheppard	(801) 288-1064	(801) 288-1065
Taylor Electric and Engineering	Chris Joyal	(801) 413-1300	(801) 413-1361
Utah Controls, Inc.	Jeff Keller	(801) 990-1950	(801) 990-1955

The bid documents (excluding drawings) will be available at 12:00 NOON on Friday, October 27, 2006 in electronic format from DFCM at 4110 State Office Building, Salt Lake City, Utah 84114, telephone (801)538-3018 and on the DFCM web page at http://dfcm.utah.gov. For questions regarding this project, please contact Jim Russell, Project Manager, DFCM, at (801)-538-9784. No others are to be contacted regarding this project. A MANDATORY pre-bid meeting and site visit will be held at 10:00 AM on Thursday, November 2, 2006 at the Provo Fourth District Court, 125 North 100 West, Provo, Utah. All pre-qualified prime contractors wishing to bid on this project must attend this meeting.

Bids must be submitted by 3:00 PM on Wednesday, November 15, 2006 to DFCM, 4110 State Office Building, Salt Lake City, Utah 84114. Bids will be opened and read aloud in the DFCM Conference Room, 4110 State Office Building, Salt Lake City, Utah. Note: Bids must be received at 4110 State Office Building by the specified time. The contractor shall comply with and require all of its subcontractors to comply with the license laws as required by the State of Utah.

A bid bond in the amount of five percent (5%) of the bid amount, made payable to the Division of Facilities Construction and Management on DFCM's bid bond form, shall accompany the bid.

The Division of Facilities Construction & Management reserves the right to reject any or all bids or to waive any formality or technicality in any bid in the interest of the State.

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT MARLA WORKMAN, CONTRACT COORDINATOR 4110 State Office Bldg., Salt Lake City, Utah 84114

STAGE II - MULTI-STEP BIDDING PROCESS

ONLY FIRMS PRE-QUALIFIED DURING STAGE I OF THE RFS ARE ALLOWED TO BID ON THIS PROJECT

1. <u>Invitational Bid Procedures</u>

The following is an overview of the invitational bid process. More detailed information is contained throughout the document. Contractors are responsible for reading and complying with all information contained in this document.

<u>Notification:</u> DFCM will notify each registered pre-qualified firm (via fax or e-mail) when a project is ready for Construction Services and invite them to bid on the project.

<u>Description of Work:</u> A description of work or plans/specifications will be given to each contractor. If required, the plans and specifications will be available on the DFCM web page at http://dfcm.utah.gov and on CDs from DFCM, at 4110 State Office Building, Salt Lake City, Utah 84114.

<u>Schedule:</u> The Stage II Schedule shows critical dates including the mandatory pre-bid site meeting (if required), the question and answer period, the bid submittal deadline, the subcontractor list submittal deadline, etc. Contractors are responsible for meeting all deadlines shown on the schedule.

<u>Mandatory Pre-Bid Site Meeting:</u> If a firm fails to attend a pre-bid site meeting labeled "Mandatory" they will not be allowed to bid on the project. At the mandatory meeting, contractors may have an opportunity to inspect the site, receive additional instructions and ask questions about project. The schedule contains information on the date, time, and place of the mandatory pre-bid site meeting.

<u>Written Questions:</u> All questions must be in writing and directed to DFCM's project manager assigned to this project. No others are to be contacted regarding this project. The schedule contains information on the deadline for submitting questions.

Addendum: All clarifications from DFCM will be in writing and issued as an addendum to the RFS. Addenda will be posted on DFCM's web site at http://dfcm.utah.gov. Contractors are responsible for obtaining information contained in each addendum from the web site. Addenda issued prior to the submittal deadline shall become part of the bidding process and must be acknowledged on the bid form. Failure to acknowledge addenda may result in disqualification from bidding.

<u>Submitting Bids:</u> Bids must be submitted to DFCM 4110 State Office Building, Salt Lake City, Utah 84114 by the deadline indicated on the schedule. Bids submitted after the deadline will not be accepted. Bids will be opened at DFCM on the date, time, and place indicated on the schedule.

<u>Subcontractors List:</u> The firm selected for the project must submit a list of all subcontractors by the deadline indicated on the schedule contained in this document.

<u>Pre-qualified List of Contractors:</u> Contractors shall remain on DFCM's list of pre-qualified contractors provided: (a) they maintain a performance rating of 4 or greater on each project, (b) they are not suspended for failure to comply with requirements of their contract, (c) the firm has not undergone a significant reorganization involving the loss of key personnel (site superintendents, project managers, owners, etc.) to a degree such that the firm no longer meets the pre-qualification requirements outlined in Stage I, (d) the financial viability of the firm has not significantly changed, and (e) the firm is not otherwise disqualified by DFCM. Note: If a contractor fails to comply with items (a) through (e) above, they may be removed from DFCM's list of pre-qualified contractors following an evaluation by a review committee. Contractors will be given the opportunity to address the review committee before a decision is made. Pre-qualified contractors are ONLY authorized to bid on projects within the discipline that they were originally pre-qualified under.

2. <u>Drawings and Specifications and Interpretations</u>

Drawings, specifications and other contract documents may be obtained as stated in the Invitation to Bid. If any firm is in doubt as to the meaning or interpretation of any part of the drawings, specifications, scope of work or contract documents, they shall submit, in writing, a request for interpretation to the authorized DFCM representative by the deadline identified in the schedule. Answers to questions and interpretations will be made via addenda issued by DFCM. Neither DFCM or the designer shall be responsible for incorrect information obtained by contractors from sources other than the official drawings/specifications and addenda issued by DFCM.

3. **Product Approvals**

Where reference is made to one or more proprietary products in the contract documents, but restrictive descriptive materials of one or more manufacturer(s) is referred to in the contract documents, the products of other manufacturers will be accepted, provided they equal or exceed the standards set forth in the drawings and specifications and are compatible with the intent and purpose of the design, subject to the written approval of the Designer. Such written approval must occur prior to the deadline established for the last scheduled addendum to be issued. The Designer's written approval will be included as part of the addendum issued by DFCM. If the descriptive material is not restrictive, the products of other manufacturers specified will be accepted without prior approval provided they are compatible with the intent and purpose of the design as determined by the Designer.

4. Addenda

All clarifications from DFCM will be in writing and issued as an addendum to the RFS. Addenda will be posted on DFCM's web site at http://dfcm.utah.gov. Contractors are responsible for obtaining information contained in each addendum from the web site. Addenda issued prior to the submittal deadline shall become part of the bidding process and must be acknowledged on the bid form. Failure to acknowledge addenda shall result in disqualification from bidding. DFCM shall not be responsible for incorrect information obtained by contractors from sources other than official addenda issued by DFCM.

5. Financial Responsibility of Contractors, Subcontractors and Sub-subcontractors

Contractors shall respond promptly to any inquiry in writing by DFCM to any concern of financial responsibility of the Contractor, Subcontractor or Sub-subcontractor. Failure to respond may result in suspension from DFCM's list of pre-qualified contractors.

6. Licensure

The Contractor shall comply with and require all of its Subcontractors to comply with the license laws as required by the State of Utah.

7. <u>Time is of the Essence</u>

Time is of the essence in regard to all the requirements of the contract documents.

8. Bids

Before submitting a bid, each bidder shall carefully examine the contract documents; shall visit the site of the work; shall fully inform themselves as to all existing conditions and limitations; and shall include in the bid the cost of all items required by the contract documents including those added via addenda. If the bidder observes that portions of the contract documents are at variance with applicable laws, building codes, rules, regulations or contain obvious erroneous or uncoordinated information, the bidder shall promptly notify the DFCM Project Manager prior to the bidding deadline. Changes necessary to correct these issues will be made via addenda issued by DFCM.

The bid, bearing original signatures, must be typed or handwritten in ink on the Bid Form provided in the procurement documents and submitted in a sealed envelope at the location specified by the Invitation to Bid prior to the published deadline for the submission of bids.

Bid bond security, in the amount of five percent (5%) of the bid, made payable to the Division of Facilities Construction and Management, shall accompany bid. THE BID BOND MUST BE ON THE BID BOND FORM PROVIDED IN THE PROCUREMENT DOCUMENTS IN ORDER TO BE CONSIDERED AN ACCEPTABLE BID.

If the bid bond security is submitted on a form other than DFCM's required bid bond form, and the bid security meets all other legal requirements, the bidder will be allowed to provide an acceptable bid bond by the close of business on the next business day following notification by DFCM of submission of a defective bid bond security. A cashier's check cannot be used as a substitute for a bid bond.

9. Listing of Subcontractors

Listing of Subcontractors shall be as summarized in the "Instructions and Subcontractor's List Form", included as part of the contract documents. The subcontractors list shall be delivered to DFCM or faxed to DFCM at (801)538-3677 within 24 hours of the bid opening. Requirements for listing additional subcontractors will be listed in the contract documents.

DFCM retains the right to audit or take other steps necessary to confirm compliance with requirements for the listing and changing of subcontractors. Any contractor who is found to not be in compliance with these requirements may be suspended from DFCM's list of pre-qualified contractors.

10. Contract and Bond

The Contractor's Agreement will be in the form provided in this document. The duration of the contract shall be for the time indicated by the project completion deadline shown on the schedule. The successful bidder, simultaneously with the execution of the Contractor's Agreement, will be required to furnish a performance bond and a payment bond, both bearing original signatures, upon the forms provided in the procurement documents. The performance and payment bonds shall be for an amount equal to one hundred percent (100%) of the Contract Sum and secured from a company that meets the requirements specified in the requisite forms. Any bonding requirements for Subcontractors will be specified in the Supplementary General Conditions.

11. Award of Contract

The Contract will be awarded as soon as possible to the lowest, responsive and responsible bidder, based on the lowest combination of base bid and acceptable prioritized alternates, provided the bid is reasonable, is in the interests of DFCM to accept and after applying the Utah Preference Laws in U.C.A. Title 63, Chapter 56. DFCM

Multi-Step Bidding Process Stage II Page No. 4

reserves the right to waive any technicalities or formalities in any bid or in the bidding. Alternates will be accepted on a prioritized basis with Alternate 1 being highest priority, Alternate 2 having second priority, etc. Alternates will be selected in prioritized order up to the construction cost estimate.

12. Right to Reject Bids

DFCM reserves the right to reject any or all Bids.

13. Withdrawal of Bids

Bids may be withdrawn on written request received from bidders within 24 hours after the bid opening if the contractor has made an error in preparing the bid.

14. DFCM Contractor Performance Rating

As a contractor completes each project, DFCM will evaluate project performance based on the enclosed "DFCM Contractor Performance Rating" form. The ratings issued on this project may affect the firm's "pre-qualified" status and their ability to obtain future work with DFCM.





Division of Facilities Construction and Management

Stage II PROJECT SCHEDULE

Project Name: FIRE ALARM UPGRADE – PROVO FOURTH DISTRICT COURT ADMINISTRATIVE OFFICE OF THE COURTS – PROVO, UTAH				
DFCM Project #:	06107150		or the coc	
Event	Day	Date	Time	Place
Stage II Bidding Documents Available	Friday	October 27, 2006	12:00 NOON	DFCM 4110 State Office Building SLC, UT and DFCM web site*
Mandatory Pre-bid Site Meeting	Thursday	November 2, 2006	10:00 AM	Provo Fourth District Court 125 North 100 West Provo, UT
Deadline for Submitting Questions	Tuesday	November 7, 2006	4:00 PM	Jim Russell - DFCM 4110 State Office Building SLC, UT
Final Addendum Issued	Thursday	November 9, 2006	4:00 PM	DFCM web site*
Prime Contractors Turn in Bid and Bid Bond / Bid Opening in DFCM Conference Room	Wednesday	November 15, 2006	3:00 PM	DFCM 4110 State Office Building SLC, UT
Subcontractors List Due	Thursday	November 16, 2006	3:00 PM	DFCM 4110 State Office Building SLC, UT
Project Completion Deadline	Thursday	March 15, 2007		

^{*} DFCM's web site address is http://dfcm.utah.gov





Division of Facilities Construction and Management

DFCM

BID FORM

NAME OF BIDDER DATE	<u> </u>	
To the Division of Facilities Construction and Management 4110 State Office Building Salt Lake City, Utah 84114		
The undersigned, responsive to the "Notice to Contractors" and in accordance we FIRE ALARM UPGRADE - PROVO FOURTH DISTRICT COURT - AD THE COURTS - PROVO, UTAH - DFCM PROJECT NO. 06107150 and has Documents and the site of the proposed Work and being familiar with all of the construction of the proposed Project, including the availability of labor, hereby proposed and supplies as required for the Work in accordance with the Contract within the time set forth and at the price stated below. This price is to cover all the Work required under the Contract Documents of which this bid is a part:	oministrative aving examined the conditions surround proposes to furnish a Documents as specifically.	OFFICE OF Contract ing the all labor, ified and
I/We acknowledge receipt of the following Addenda: For all work shown on the Drawings and described in the Specifications and Corperform for the sum of:	ntract Documents, I	/we agree to
(In case of discrepancy, written amount shall govern)	ARS (\$	_)
I/We guarantee that the Work will be Substantially by Thursday, March 15, 20 bidder, and agree to pay liquidated damages in the amount of \$250.00 per day for Contract Time as stated in Article 3 of the Contractor's Agreement.		
This bid shall be good for 45 days after bid opening.		
Enclosed is a 5% bid bond, as required, in the sum of		
The undersigned Contractor's License Number for Utah is		

BID FORM PAGE NO. 2

Upon receipt of notice of award of this bid, the undersigned agrees to execute the contract within ten (10) days, unless a shorter time is specified in Contract Documents, and deliver acceptable Performance and Payment bonds in the prescribed form in the amount of 100% of the Contract Sum for faithful performance of the contract. The Bid Bond attached, in the amount not less than five percent (5%) of the above bid sum, shall become the property of the Division of Facilities Construction and Management as liquidated damages for delay and additional expense caused thereby in the event that the contract is not executed and/or acceptable 100% Performance and Payment bonds are not delivered within time set forth.

Type of Organization:		
	(Corporation, Partnership, Individu	ual, etc.)
Any request and inform	nation related to Utah Preference La	ws:
	Respectfu	illy submitted,
	Name of I	Bidder
	ADDRES	S:
	Authorize	ed Signature

BID BOND (Title 63, Chapter 56, U. C. A. 1953, as Amended)

KNOW ALL PERSONS BY THESE PRESENTS:

That	hereinafter referred to as the
"Principal," and	, a corporation organized and existing under
this State and U.S. Department of the Treasury Listed (Circular 570 Compa	and authorized to transact dusiness in an estimate Holding Certificates of Authority as Acceptable Securities on
Federal Bonds and as Acceptable Reinsuring Companies); hereinafter referre	ed to as the "Surety," are held and firmly bound unto the STATE OF
UTAH, hereinafter referred to as the "Obligee," in the amount of \$ the sum of this Bond to which payment the Principal and Surety bind themse	(5% of the accompanying bid), being
the sum of this Bond to which payment the Principal and Surety bind themse	lves, their heirs, executors, administrators, successors and assigns,
jointly and severally, firmly by these presents.	
THE CONDITION OF THIS OBLIGATION IS SUCH that when the condition of the co	nereas the Principal has submitted to Obligee the accompanying bid
incorporated by reference herein, dated as shown, to enter into a contract in	n writing for the
-	Project.
NOW, THEREFORE, THE CONDITION OF THE ABOVE O	ADLICATION IS SUCIL that if the said principal does not execute
a contract and give bond to be approved by the Obligee for the faithful perfo	
of such contract to the principal, then the sum of the amount stated above will	Il be forfeited to the State of Utah as liquidated damages and not as
a penalty; if the said principal shall execute a contract and give bond to be ap	pproved by the Obligee for the faithful performance thereof within
ten (10) days after being notified in writing of such contract to the Princ	ipal, then this obligation shall be null and void. It is expressly
understood and agreed that the liability of the Surety for any and all defaults The Surety, for value received, hereby stipulates and agrees that obligations	of the Principal hereunder shall be the full penal sum of this Bond.
from actual date of the bid opening.	of the streety thiter this bond shall be for a term of sixty (60) tays
PROVIDED, HOWEVER, that this Bond is executed pursuant to	provisions of Title 63, Chapter 56, Utah Code Annotated, 1953, as
amended, and all liabilities on this Bond shall be determined in accordance herein.	with said provisions to same extent as if it were copied at length
nerem.	
IN WITNESS WHEREOF, the above bounden parties have exec	cuted this instrument under their several seals on the date indicated
below, the name and corporate seal of each corporate party being hereto affixed	ed and these presents duly signed by its undersigned representative,
pursuant to authority of its governing body.	
DATED this day of, 20	
, 20	
Principal's name and address (if other than a corporation):	Principal's name and address (if a corporation):
	
D	D
By:	By:
Title:	Title:
	Title:(Affix Corporate Seal)
	Surety's name and address:
	Surety's name and address.
STATE OF)	
) ss.	By:
COUNTY OF	By:
	11. 6
On this day of, 20, personally appeare whose identity is personally known to me or proved to me on the basis of sat	d before me, risfactory evidence, and who being by me duly sworn, did say that
he/she is the Attorney-in-fact of the above-named Surety Company, and that	the/she is duly authorized to execute the same and has complied in
all respects with the laws of Utah in reference to becoming sole surety upon l	oonds, undertakings and obligations, and that he/she acknowledged
to me that as Attorney-in-fact executed the same.	
Subscribed and sworn to before me this day of	20
Subscribed and sworn to before me this day of My Commission Expires:	, 20
My Commission Expires:	, 20
Subscribed and sworn to before me this day of My Commission Expires: Resides at:	
My Commission Expires: Resides at:	NOTARY PUBLIC
My Commission Expires: Resides at: Agency: Agent:	
My Commission Expires: Resides at:	





Division of Facilities Construction and Management

INSTRUCTION AND SUBCONTRACTORS LIST FORM

The three low bidders, as well as all other bidders that desire to be considered, are required by law to submit to DFCM within 24 hours of bid opening a list of <u>ALL</u> first-tier subcontractors, including the subcontractor's name, bid amount and other information required by Building Board Rule and as stated in these Contract Documents, on the following basis:

PROJECTS UNDER \$500,000 - ALL SUBS \$20,000 OR OVER MUST BE LISTED PROJECTS \$500,000 OR MORE - ALL SUBS \$35,000 OR OVER MUST BE LISTED

- Any additional subcontractors identified in the bid documents shall also be listed.
- The DFCM Director may not consider any bid submitted by a bidder if the bidder fails to submit a subcontractor list meeting the requirements of State law.
- List subcontractors for base bid as well as the impact on the list that the selection of any alternate may have.
- Bidder may not list more than one subcontractor to perform the same work.
- Bidder must list "Self" if performing work itself.

LICENSURE:

The subcontractor's name, the type of work, the subcontractor's bid amount, and the subcontractor's license number as issued by DOPL, if such license is required under Utah Law, shall be listed. Bidder shall certify that all subcontractors, required to be licensed, are licensed as required by State law. A subcontractor includes a trade contractor or specialty contractor and does not include suppliers who provide <u>only</u> materials, equipment, or supplies to a contractor or subcontractor.

BIDDER LISTING 'SELF' AS PERFORMING THE WORK:

Any bidder that is properly licensed for the particular work and intends to perform that work itself in lieu of a subcontractor that would otherwise be required to be on the subcontractor list, must insert the term 'Self' for that category on the subcontractor list form. Any listing of 'Self' on the sublist form shall also include the amount allocated for that work.

'SPECIAL EXCEPTION':

A bidder may list 'Special Exception' in place of a subcontractor when the bidder intends to obtain a subcontractor to perform the work at a later date because the bidder was unable to obtain a qualified or reasonable bid under the provisions of U.C.A.Section 63A-5-208(4). The bidder shall insert the term 'Special Exception' for that category of work, and shall provide documentation with the subcontractor list describing the bidder's efforts to obtain a bid of a qualified subcontractor at a reasonable cost and why the bidder was unable to obtain a qualified subcontractor bid. The Director must find that the bidder complied in good faith with State law requirements for any 'Special Exception' designation, in order for the bid to be considered. If awarded the contract, the Director shall supervise the bidder's efforts to obtain a qualified subcontractor bid. The amount of the awarded contract may not be adjusted to reflect the actual amount of the subcontractor's bid. Any listing of 'Special Exception' on the sublist form shall also include amount allocated for that work.

INSTRUCTIONS AND SUBCONTRACTORS LIST FORM Page No. 2

GROUNDS FOR DISQUALIFICATION:

The Director may not consider any bid submitted by a bidder if the bidder fails to submit a subcontractor list meeting the requirements of State law. Director may withhold awarding the contract to a particular bidder if one or more of the proposed subcontractors are considered by the Director to be unqualified to do the Work or for such other reason in the best interest of the State of Utah. Notwithstanding any other provision in these instructions, if there is a good faith error on the sublist form, at the sole discretion of the Director, the Director may provide notice to the contractor and the contractor shall have 24 hours to submit the correction to the Director. If such correction is submitted timely, then the sublist requirements shall be considered met.

CHANGES OF SUBCONTRACTORS SPECIFICALLY IDENTIFIED ON SUBLIST FORM:

Subsequent to twenty-four hours after the bid opening, the contractor may change its listed subcontractors only after receiving written permission from the Director based on complying with all of the following criteria.

- (1) The contractor has established in writing that the change is in the best interest of the State and that the contractor establishes an appropriate reason for the change, which may include, but not is not limited to, the following reasons: the original subcontractor has failed to perform, or is not qualified or capable of performing, and/or the subcontractor has requested in writing to be released.
- (2) The circumstances related to the request for the change do not indicate any bad faith in the original listing of the subcontractors.
- (3) Any requirement set forth by the Director to ensure that the process used to select a new subcontractor does not give rise to bid shopping.
- (4) Any increase in the cost of the subject subcontractor work is borne by the contractor.
- (5) Any decrease in the cost of the subject subcontractor work shall result in a deductive change order being issued for the contract for such decreased amount.
- (6) The Director will give substantial weight to whether the subcontractor has consented in writing to being removed unless the Contractor establishes that the subcontractor is not qualified for the work.

EXAMPLE:

Example of a list where there are only four subcontractors:

TYPE OF WORK	SUBCONTRACTOR, "SELF" OR "SPECIAL EXCEPTION"	SUBCONTRACTOR BID AMOUNT	CONT. LICENSE #
ELECTRICAL	ABCD Electric Inc.	\$350,000.00	123456789000
LANDSCAPING	"Self"	300,000.00	123456789000
CONCRETE (ALTERNATE #1)	XYZ Concrete Inc	298,000.00	987654321000
MECHANICAL	"Special Exception" (attach documentation)	Fixed at: 350,000.00	(TO BE PROVIDED AFTER OBTAINING SUBCONTRACTOR)

PURSUANT TO STATE LAW - SUBCONTRACTOR BID AMOUNTS CONTAINED IN THIS SUBCONTRACTOR LIST SHALL NOT BE DISCLOSED UNTIL THE CONTRACT HAS BEEN AWARDED.



DDO IFCT TITLE.

Division of Facilities Construction and Management

DFCM

SUBCONTRACTORS LIST FAX TO 801-538-3677

TYPE OF WORK	SUBCONTRACTOR, "SELF" OR "SPECIAL EXCEPTION"	SUBCONTRACTOR BID AMOUNT	CONT. LICENSE
alternates. We have listed "Self" or "Spec	ctors as required by the instructions, including cial Exception" in accordance with the instructionately licensed as required by State law.		bid as well as an
	FIRM:		
E:	SIGNED BY:		

DFCM Form 7b 060706

IN THESE CONTRACT DOCUMENTS, SHALL BE GROUNDS FOR DFCMS REFUSAL TO ENTER INTO A WRITTEN CONTRACT WITH BIDDER. ACTION MAY BE TAKEN AGAINST BIDDERS BID BOND

AS DEEMED APPROPRIATE BY DFCM. ATTACH A SECOND PAGE IF NECESSARY.

FUGITIVE DUST PLAN

The Contractor will fill out the form and file the original with the Division of Air Quality and a copy of the form with the Division of Facilities Construction & Management, prior to the issuance of any notice to proceed.

The Contractor will be fully responsible for compliance with the Fugitive Dust Control Plan, including the adequacy of the plan, any damages, fines, liability, and penalty or other action that results from noncompliance.

Page 1 of 7

Utah Division of Air Quality April 20, 1999


GUIDANCE THAT MUST BE CONSIDERED IN DEVELOPING AND SUBMITTING A DUST CONTROL PLAN FOR COMPLIANCE WITH R307-309-3, 4, 5, 6, 7

Source Information:

1.	Name of your operation (source): provide a name if the source is a construction site.
2.	Address or location of your operation or construction site.
3.	UTM coordinates or Longitude/Latitude of stationary emission points at your operation.
4.	Lengths of the project, if temporary (time period).
5.	Description of process (include all sources of dust and fugitive dust). Please, if necessary, use additional sheets of paper for this description. Be sure to mark it as an attachment.
6.	Type of material processed or disturbed.
7.	Amount of material processed (tons per year, tons per month, lbs./hr., and applicable units).

DFCM Form 7b 060706

Page 2 of 7



Description of Fugitive Dust Emission Activities (Things to consider in addressing fugitive dust control strategies.)

1.	Type of activities (drilling and blasting, road construction, development construction, earth moving and excavation, handling and hauling materials, cleaning and leveling, etc).
2.	List type of equipment generating the fugitive dust.
3.	Diagram the location of each activity or piece of equipment on site. Please attach the diagram.
4.	Provide pictures or drawings of each activity. Include a drawing of the unpaved/paved road network used to move loads "on" and "off" property.
5.	Vehicle miles travels on unpaved roads associated with the activity (average speed).
6.	Type of dust emitted at each source (coal, cement, sand, soil, clay, dust, etc.)
7.	Estimate the size of the release area at which the activity occurs (square miles). For haul or dirt roads include total miles of road in use during the activity.

DFCM Form 7b 060706

Page 4 of 7

Description of Fugitive Dust Emission Controls on Site

Control strategies must be designed to meet 20% opacity or less on site (a lesser opacity may be defined by Approval Order conditions or federal requirements such as NSPS), and control strategies must prevent exceeding 10% opacity from fugitive dust at the property boundary (site boundary) for compliance with R307-309-3.

1.	Types of ongoing emission controls proposed for each activity, each piece of equipment, and haul roads.
2.	Types of additional dust controls proposed for bare, exposed surfaces (chemical stabilization, synthetic cover, wind breaks, vegetative cover, etc).
3.	Method of application of dust suppressant.
4.	Frequency of application of dust suppressant.
5.	Explain what triggers the use of a special control measure other than routine measures already in place, such as covered loads or measures covered by a permit condition (increase in opacity, high winds, citizen complaints, dry conditions, etc).
6.	Explain in detail what control strategies/measures will be implemented off-hours, i.e., Saturdays/Sundays/Holidays, as well as 6 PM to 6 AM each day.

DFCM Form 7b 060706

Page 5 of 7

Description of Fugitive Dust Control Off-site

Prevent, to the maximum extent possible, deposition of materials, which may create fugitive dust on public and private paved roads in compliance with R307-309-5, 6, 7.

1. Types of emission controls initiated by your operation that are in place "off" property (application of water, covered loads, sweeping roads, vehicle cleaning, etc.).

2. Proposed remedial controls that will be initiated promptly if materials, which may create fugitive dust, are deposited on public and private paved roads.

Phone: (801) 536-4000

FAX:

(801) 536-4099

Submit the Dust Control Plan to:

Executive Secretary Utah Air Quality Board POB 144820 15 North 1950 West Salt Lake City, Utah 84114-4820

Page 6 of 7

Fugitive Dust Control Plan Violation Report

When a source is found in violation of R307-309-3 or in violation of the Fugitive Dust Control Plan, the course must submit a report to the Executive Secretary within 15 days after receiving a Notice of Violation. The report must include the following information:

- 1. Name and address of dust source.
- 2. Time and duration of dust episode.
- 3. Meteorological conditions during the dust episode.
- 4. Total number and type of fugitive dust activities and dust producing equipment within each operation boundary. If no change has occurred from the existing dust control plan, the source should state that the activity/equipment is the same.
- 5. Fugitive dust activities or dust producing equipment that caused a violation of R-307-309-3 or the sources dust control plan.
- 6. Reasons for failing to control dust from the dust generating activity or equipment.
- 7. New and/or additional fugitive dust control strategies necessary to achieve compliance with R307-309-3, 4, 5, 6, or 7.
- 8. If it can not be demonstrated that the current approved Dust Control Plan can result in compliance with R307-309-3 through 7, the Dust Control Plan must be revised so as to demonstrate compliance with 307-309-3 through 7. Within 30 days of receiving a fugitive dust Notice of Violation, the source must submit the revised Plan to the Executive Secretary for review and approval.

Submit the Dust Control Plan to:

Executive Secretary Phone: (801) 536-4000 Utah Air Quality Board FAX: (801) 536-4099

POB 144820

DFCM Form 7b 060706

15 North 1950 West

Salt Lake City, Utah 84114-4820

Attachments: DFCM Form FDR R-307-309, Rule 307-309

Page 7 of 7

21

300/300/	/FVA/	/	/	/
	Project	No.		

CONTRACTOR'S AGREEMENT

FOR:			
THIS CONTRACTOR'S AGREEMENT, made and between the DIVISION OF FACILITIES of referred to as "DFCM", and and authorized to do business in whose address is	CONSTRUCTION AND inco the State of Utah, herein	MANAGEMEN'	T, hereinafter
WITNESSETH: WHEREAS, DFCM intends t		at	
WHEREAS, Contractor agrees to perform the		herein.	
NOW, THEREFORE, DFCM and Contractor for Agreement, agree as follows:	or the consideration prov	vided in this Contr	ractor's
ARTICLE 1. SCOPE OF WORK. The Work Contract Documents prepared by		22	
The DFCM General Conditions ("General ConDFCM and available on the DFCM website, and Agreement and are included in the specification Agreement shall be as defined in the Contract I	ditions") dated May 25, e hereby incorporated by ns for this Project. All to	2005 on file at the reference as part erms used in this (of this Contractor's
The Contractor Agrees to furnish labor, material Contract Documents which are hereby incorpor parties hereto that all Work shall be performed subject to inspection and approval of DFCM or Contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of an armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of armonic contractor to the DFCM hereunder is that of a contractor to the DFCM hereunder is the armonic contractor to the DFCM hereunder is the armonic contractor to the DFCM hereunder is the armonic contractor to	rated by reference. It is as required in the Contra its authorized represent	understood and ag act Documents and ative. The relation	greed by the d shall be
ARTICLE 2. CONTRACT SUM. The DFC full performance of this Contractor's Agreemen	it, the sum of	C	•
is the base bid, and which sum also includes the	_ DOLLARS AND NO e cost of a 100%	CENTS (\$	00), which

CONTRACTOR'S AGREEMENT PAGE NO 2

Performance Bond and a 100% Payment Bond as well as all insurance requirements of the Contractor. Said bonds have already been posted by the Contractor pursuant to State law. The required proof of insurance certificates have been delivered to DFCM in accordance with the General Conditions before the execution of this Contractor's Agreement.

ARTICLE 3. TIME OF COMPLETION AND DELAY REMEDY. The Work shall be
Substantially Complete within () calendar days after the date of the Notice to
Proceed. Contractor agrees to pay liquidated damages in the amount of \$ per day for each day
after expiration of the Contract Time until the Contractor achieves Substantial Completion in accordance
with the Contract Documents, if Contractor's delay makes the damages applicable. The provision for
liquidated damages is: (a) to compensate the DFCM for delay only; (b) is provided for herein because
actual damages can not be readily ascertained at the time of execution of this Contractor's Agreement;
(c) is not a penalty; and (d) shall not prevent the DFCM from maintaining Claims for other non-delay
damages, such as costs to complete or remedy defective Work.

No action shall be maintained by the Contractor, including its or Subcontractor or suppliers at any tier, against the DFCM or State of Utah for damages or other claims due to losses attributable to hindrances or delays from any cause whatsoever, including acts and omissions of the DFCM or its officers, employees or agents, except as expressly provided in the General Conditions. The Contractor may receive a written extension of time, signed by the DFCM, in which to complete the Work under this Contractor's Agreement in accordance with the General Conditions.

ARTICLE 4. CONTRACT DOCUMENTS. The Contract Documents consist of this Contractor's Agreement, the Conditions of the Contract (DFCM General Conditions, Supplementary and other Conditions), the Drawings, Specifications, Addenda and Modifications. The Contract Documents shall also include the bidding documents, including the Notice to Contractors, Instructions to Bidders/Proposers and the Bid/Proposal, to the extent not in conflict therewith and other documents and oral presentations that are documented as an attachment to the contract.

All such documents are hereby incorporated by reference herein. Any reference in this Contractor's Agreement to certain provisions of the Contract Documents shall in no way be construed as to lessen the importance or applicability of any other provisions of the Contract Documents.

ARTICLE 5. PAYMENT. The DFCM agrees to pay the Contractor from time to time as the Work progresses, but not more than once each month after the date of Notice to Proceed, and only upon Certificate of the A/E for Work performed during the preceding calendar month, ninety-five percent (95%) of the value of the labor performed and ninety-five percent (95%) of the value of materials furnished in place or on the site. The Contractor agrees to furnish to the DFCM invoices for materials purchased and on the site but not installed, for which the

CONTRACTOR'S AGREEMENT PAGE NO. 3

Contractor requests payment and agrees to safeguard and protect such equipment or materials and is responsible for safekeeping thereof and if such be stolen, lost or destroyed, to replace same.

Such evidence of labor performed and materials furnished as the DFCM may reasonably require shall be supplied by the Contractor at the time of request for Certificate of Payment on account. Materials for which payment has been made cannot be removed from the job site without DFCM's written approval. Five percent (5%) of the earned amount shall be retained from each monthly payment. The retainage, including any additional retainage imposed and the release of any retainage, shall be in accordance with UCA 13-8-5 as amended. Contractor shall also comply with the requirements of UCA 13-8-5, including restrictions of retainage regarding subcontractors and the distribution of interest earned on the retention proceeds. The DFCM shall not be responsible for enforcing the Contractor's obligations under State law in fulfilling the retention law requirements with subcontractors at any tier.

ARTICLE 6. INDEBTEDNESS. Before final payment is made, the Contractor must submit evidence satisfactory to the DFCM that all payrolls, materials bills, subcontracts at any tier and outstanding indebtedness in connection with the Work have been properly paid. Final Payment will be made after receipt of said evidence, final acceptance of the Work by the DFCM as well as compliance with the applicable provisions of the General Conditions.

Contractor shall respond immediately to any inquiry in writing by DFCM as to any concern of financial responsibility and DFCM reserves the right to request any waivers, releases or bonds from Contractor in regard to any rights of Subcontractors (including suppliers) at any tier or any third parties prior to any payment by DFCM to Contractor.

ARTICLE 7. ADDITIONAL WORK. It is understood and agreed by the parties hereto that no money will be paid to the Contractor for additional labor or materials furnished unless a new contract in writing or a Modification hereof in accordance with the General Conditions and the Contract Documents for such additional labor or materials has been executed. The DFCM specifically reserves the right to modify or amend this Contractor's Agreement and the total sum due hereunder either by enlarging or restricting the scope of the Work.

ARTICLE 8. INSPECTIONS. The Work shall be inspected for acceptance in accordance with the General Conditions.

ARTICLE 9. DISPUTES. Any dispute, PRE or Claim between the parties shall be subject to the provisions of Article 7 of the General Conditions. DFCM reserves all rights to pursue its rights and remedies as provided in the General Conditions.

ARTICLE 10. TERMINATION, SUSPENSION OR ABANDONMENT. This Contractor's Agreement may be terminated, suspended or abandoned in accordance with the General Conditions.

ARTICLE 11. DFCM'S RIGHT TO WITHHOLD CERTAIN AMOUNT AND MAKE USE THEREOF. The DFCM may withhold from payment to the Contractor such amount as, in DFCM's judgment, may be necessary to pay just claims against the Contractor or Subcontractor at any tier for labor and services rendered and materials furnished in and about the Work. The DFCM may apply such withheld amounts for the payment of such claims in DFCM's discretion. In so doing, the DFCM shall be deemed the agent of Contractor and payment so made by the DFCM shall be considered as payment made under this Contractor's Agreement by the DFCM to the Contractor. DFCM shall not be liable to the Contractor for any such payment made in good faith. Such withholdings and payments may be made without prior approval of the Contractor and may be also be prior to any determination as a result of any dispute, PRE, Claim or litigation.

ARTICLE 12. INDEMNIFICATION. The Contractor shall comply with the indemnification provisions of the General Conditions.

ARTICLE 13. SUCCESSORS AND ASSIGNMENT OF CONTRACT. The DFCM and Contractor, respectively bind themselves, their partners, successors, assigns and legal representatives to the other party to this Agreement, and to partners, successors, assigns and legal representatives of such other party with respect to all covenants, provisions, rights and responsibilities of this Contractor's Agreement. The Contractor shall not assign this Contractor's Agreement without the prior written consent of the DFCM, nor shall the Contractor assign any moneys due or to become due as well as any rights under this Contractor's Agreement, without prior written consent of the DFCM.

ARTICLE 14. RELATIONSHIP OF THE PARTIES. The Contractor accepts the relationship of trust and confidence established by this Contractor's Agreement and covenants with the DFCM to cooperate with the DFCM and A/E and use the Contractor's best skill, efforts and judgment in furthering the interest of the DFCM; to furnish efficient business administration and supervision; to make best efforts to furnish at all times an adequate supply of workers and materials; and to perform the Work in the best and most expeditious and economic manner consistent with the interests of the DFCM.

ARTICLE 15. AUTHORITY TO EXECUTE AND PERFORM AGREEMENT. Contractor and DFCM each represent that the execution of this Contractor's Agreement and the performance thereunder is within their respective duly authorized powers.

ARTICLE 16. ATTORNEY FEES AND COSTS. Except as otherwise provided in the dispute resolution provisions of the General Conditions, the prevailing party shall be entitled to reasonable attorney fees and costs incurred in any action in the District Court and/or appellate body to enforce this Contractor's Agreement or recover damages or any other action as a result of a breach thereof.

CONTRACTOR'S AGREEMENT PAGE NO. 5

IN WITNESS WHEREOF, the parties hereto have executed this Contractor's Agreement on the day and year stated hereinabove.

	CONTRACTOR:				
	Signature	Date			
	Title:				
State of)					
County of)	Please type/print name clearly				
On this day of, 20, per whose identity is personally known to me (or who by me duly sworn (or affirmed), did say the firm and that said document was signed be	sonally appeared before me, that he (she) is the (title y him (her) in behalf of said firm.	dence) and or office)			
(SEAL)	Notary Public My Commission Expires				
APPROVED AS TO AVAILABILITY OF FUNDS:	DIVISION OF FACILITIES CONSTRUCTION AND MANAGE	EMENT			
Financial Manager, Date Division of Facilities Construction and Management	Manager - Capital	Date			
APPROVED AS TO FORM: ATTORNEY GENERAL May 25, 2005	APPROVED FOR EXPENDITURE:				
By: Alan S. Bachman Asst Attorney General	Division of Finance	Date			

PERFORMANCE BOND

(Title 63, Chapter 56, U. C. A. 1953, as Amended)

That	h	ereinafter referred to as the	ie "Principal" and
, with its principal office in the City of and authorized			
Listed (Circular 570, Companies Holding Certificates of Authority as Acceptable Secu	rities on Federal Bonds	and as Acceptable Reins	suring Companies);
hereinafter referred to as the "Surety," are held and firmly bound unto the State of Utah,	hereinafter referred to as	the "Obligee, " in the am	ount of
	DOLLARS (\$) for the pa	yment whereof, the
said Principal and Surety bind themselves and their heirs, administrators, executors, succ	cessors and assigns, jointl	ly and severally, firmly by	y these presents.
	<i>و ہ</i>		ī
WHEREAS, the Principal has entered into a certain written Contract with the	e Obligee, dated the	day of	. 20 . to
construct			, 1, 11
in the County of, State of Utah, Project No, Contract is hereby incorporated by reference herein	for the approximate sum	of	
	or the approximate same	Dollars (\$) which
Contract is hereby incorporated by reference herein.		Donais (\$), wincii
Contract is necessy incorporated by reference necessi.			
NOW THEREFORE 4 17 C41 11 C 1 14 CC4 1	ID: : 1.1 HC:4CH	C 4 C + +:	1 24.4
NOW, THEREFORE, the condition of this obligation is such that if the said			
Contract Documents including, but not limited to, the Plans, Specifications and condition			
Contract as said Contract may be subject to Modifications or changes, then this obligation	on shall be void; otherwis	e it shall remain in full fo	rce and effect.
No right of action shall accrue on this bond to or for the use of any person or	corporation other than the	ne state named herein or t	he heirs, executors,
administrators or successors of the Owner.			
The parties agree that the dispute provisions provided in the Contract Docume	nts apply and shall constit	tute the sole dispute proce	dures of the parties.
PROVIDED, HOWEVER, that this Bond is executed pursuant to the Provis	ions of Title 63. Chapter	56. Utah Code Annotated	. 1953, as amended.
and all liabilities on this Bond shall be determined in accordance with said provisions to			
IN WITNESS WHEREOF, the said Principal and Surety have signed and s	ealed this instrument this	day of	20
114 WITHERS WITHERST, the said Timespar and Surety have signed and s	carea una matrament una	day or	, 20
WITNESS OD ATTESTATION.	PRINCIPAL:		
WITNESS OR ATTESTATION:	rkinciral;		
	By:		
			(Seal)
	Title:		
WITNESS OR ATTESTATION:	SURETY:		
	-		
	By:		
	Attorney-in-Fact		(Seal)
OTATE OF	Attorney-III-ract		(Seal)
STATE OF)			
) ss.			
COUNTY OF)			
On this day of, 20, personally appeared before me			, whose
identity is personally known to me or proved to me on the basis of satisfactory evidence	and who, being by me do	uly sworn, did say that he	/she is the Attorney
in-fact of the above-named Surety Company and that he/she is duly authorized to execu	ate the same and has com-	plied in all respects with	the laws of Utah in
reference to becoming sole surety upon bonds, undertakings and obligations, and that he	she acknowledged to me	e that as Attorney-in-fact	executed the same.
	· ·	·	
Subscribed and sworn to before me this day of	20		
	., = v		
My commission expires:			
Resides at:	NOTA DV PUDLIC		
	NOTARY PUBLIC		
Agency:			
Agent:			
Address:		Approved As To Form	m. May 25 2005
Phone:	R _v A1	Approved As 10 Fort	

PAYMENT BOND

(Title 63, Chapter 56, U. C. A. 1953, as Amended)

KNOW ALL PERSONS BY THESE PRESENTS:

That	hereinafter referred to as the "Principal," and				
and U. S. Department of the	, a corporation organized and existing under the Treasury Listed (Circular 570, Companies Ho	he laws of the State of lding Certificates of Authority as Ac	authorized to do business in this State ceptable Securities on Federal Bonds and as		
	panies); with its principal office in the City of _				
the State of Utah hereinafter	referred to as the "Obligee," in the amount of) for the payment whereof, the said Principal references to the payment whereof in the said Principal references to the said Principal reference	-1 d C	:-1-:		
	erally, firmly by these presents.	at and Surety bind themselves and the	ir neirs, administrators, executors, successors		
WHEDEAS the	Principal has entered into a certain written Con	street with the Obligate detail the	day of 20		
in the County of	, State of Utah, Project No	for the approximate sum of	of		
	,,, ., .,	Dollars (\$), which contract is hereby		
incorporated by reference he					
or Principal's Subcontractors	FORE, the condition of this obligation is such that is in compliance with the provisions of Title 63, Contract, then, this obligation shall be void; other	Chapter 56, of Utah Code Annotated, 19	953, as amended, and in the prosecution of the		
of the Contract or to the Wor and does hereby waive notic	to this Bond, for value received, hereby stipulates k to be performed thereunder, or the specification e of any such changes, extensions of time, altera they shall become part of the Contract Documer	as or drawings accompanying same sha tions or additions to the terms of the C	ll in any way affect its obligation on this Bond		
	OWEVER, that this Bond is executed pursuant to nall be determined in accordance with said provide				
IN WITNESS V	WHEREOF, the said Principal and Surety have	signed and sealed this instrument this	day of, 20		
WITNESS OR ATTESTA	TION:	PRINCIPAL:			
		By:	(Seal)		
		Title:	(301)		
WITNESS OR ATTESTA	TION:	SURETY:			
OTATE OF		By:			
STATE OF)) ss.	Attorney-in-Fact	(Seal)		
COUNTY OF					
On this	day of, 20,		known to me or proved to me on the basis or		
authorized to execute the sa	ho, being by me duly sworn, did say that he/she ame and has complied in all respects with the lacknowledged to me that as Attorney-in-fact ex	is the Attorney-in-fact of the above-na aws of Utah in reference to becomin	med Surety Company, and that he/she is duly		
Subscribed and sworn to be	fore me this day of	, 20			
My commission expires:					
-					
		NOTARY PUBLIC			
Agency:					
Agent:			Approved As To Form: May 25, 2005		
Address:		I	By Alan S. Bachman, Asst Attorney General		
Phone.		II	•		



Page _____ of ____page(s)



Division of Facilities Construction and Management

СН	ANGE ORDE	R #				
CON	DNTRACTOR: AGENCY OR INSTITUTION: PROJECT NAME: PROJECT NUMBER:					
ARCI	HITECT:			NTRACT NUME TE:	BER:	
	CONSTRUCTION PROPOSAL		AMC	MOUNT		YS
	CHANGE DIRECTIVE NO.	REQUEST NO.	INCREASE	DECREASE	INCREASE	DECREASE
						-
				Amount	Days	Date
	ORIGINAL CONTRA	ACT				
	TOTAL PREVIOUS CHANGE ORDERS					
	TOTAL THIS CHANGE ORDER					
	ADJUSTED CONTRACT					
shall indire	A and Contractor agree constitute the full accor ct costs and effects rel scope of the Work and	rd and satisfactio ated to, incidenta	n, and complete	adjustment to the	he Contract and	d includes all direct a
Contr	actor:					
Archi	tect/Engineer:)ate
Agen	cy or Institution:)ate
	Л:				D	Pate
	ng Verification:					ate
. and	g voimoudon				D	Date



Division of Facilities Construction and Management

DFCM

CERTIFICATE OF SUBSTANTIAL COMPLETION

PROJECT		PROJI	ECT NO:	
AGENCY/INSTITUTION				
AREA ACCEPTED				
The Work performed under the subject Cond defined in the General Conditions; including Documents, as modified by any change orders area of the Project for the use for which it is	that the cagreed to b	onstruction is sufficiently	completed in accord	lance with the Contract
The DFCM - (Owner) accepts the Project or possession of the Project or specified area of				
The DFCM accepts the Project for occupancy utilities and insurance, of the Project subject				
The Owner acknowledges receipt of the follo ☐ Record Drawings ☐ O & M Ma		eout and transition material Warranty Documents		on of Training eents
A list of items to be completed or corrected (Presponsibility of the Contractor to complete changes thereof. The amount of completion of the punch list work.	all the Wo	ork in accordance with the	e Contract Document	s, including authorized
The Contractor shall complete or correct the calendar days from the above date of issue the Owner has the right to be compensated for expense of the retained project funds. If the Owner shall be promptly reimbursed for the least of the lea	nance of thi the delays retained pro	s Certificate. If the list of and/or complete the work oject funds are insufficien	items is not completed with the help of indep t to cover the delay/co	l within the time allotted endent contractor at the
-	by:			
CONTRACTOR (include name of firm)		(Signature)		DATE
A/E (include name of firm)	by:	(Signature)		DATE
USING INSTITUTION OR AGENCY	by:	(Signature)		DATE
DFCM (Owner)	by:	(Signature)		DATE
4110 State Office Building, Salt Lake City, Utelephone 801-538-3018 • facsimile 801-538-		4	ce:	Parties Noted DFCM, Director

SECTION 13851 - FIRE ALARM SYSTEM

PART I - GENERAL

1.01 RELATED DOCUMENTS:

A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and General Requirements, apply to the work specified in this section.

1.02 <u>DESCRIPTION OF WORK:</u>

A. This section of the specifications includes the demolition of existing fire alarm system and furnishing, installation, connection and testing of new microprocessor controlled, intelligent reporting fire alarm equipment required to form a complete, operative, coordinated system to protect the building housing the Administrative Office of the Courts in Provo, UT. Fire alarm system shall include, but not be limited to, alarm initiating devices, alarm notification appliances, Fire Alarm Control Panel (FACP), remote power supplies, auxiliary control devices and relays, door hold-open devices, annunciators, conduit and wiring as shown on the drawings and specified herein.

1.03 QUALITY ASSURANCE:

- A. The fire alarm system shall comply with requirements of NFPA 72 (National Fire Alarm Code) for Local Protected Premises Signaling Systems except as modified and supplemented by this specification. The system field wiring shall be supervised either electrically or by software-directed polling of field devices.
- B. Major system components (control panels, initiating devices, addressable modules or relays, power supplies, etc.) shall be manufactured by a State of Utah DFCM approved manufacturer.
- C. State of Utah DFCM Approved Manufacturers:
 - 1. Fire-Lite
 - 2. Silent Knight
- D. All initiating devices shall be listed compatible with the control equipment used.
- E. Materials, devices and equipment shall be Underwriters Laboratories (UL) listed or Factory Mutual approved for use in fire alarm systems and shall comply with all applicable requirements of the following UL standards:
 - 1. UL 38 Manually Actuated Signaling Boxes
 - 2. UL 50 Cabinets and Boxes
 - 3. UL 864 Control Units for Fire Protective Signaling Systems
 - 4. UL 268 Smoke Detectors for Fire Protective Signaling Systems
 - 5. UL 268A Smoke Detectors for Duct Applications
 - 6. UL 464 Audible Signaling Appliances
 - 7. UL 521 Heat Detectors for Fire Protective Signaling Systems
 - 8. UL 1971 Visual Notification Appliances.
- F. Shop drawings shall be prepared by an engineering technician or senior engineering technician (Level III or Level IV) NICET certified for fire alarm design. Include NICET certification number on the drawings. Drawings will be signed by the technician and submitted for approval

under his name.

G. Contractor (and/or subcontractor) shall be licensed as both an electrical and a fire alarm contractor in the State of Utah. License shall be active throughout the duration of the project.

1.04 SUBMITTALS:

- A. <u>Descriptive Data</u>: Descriptive data shall be submitted on the following items of material and/or equipment. Such data shall consist of manufacturer's or supplier's catalog information in sufficient detail to allow verification that the material and/or equipment meets the specification requirements, or is equal to that specified. Descriptive data shall be included with the shop drawings submittal described in paragraph B below.
 - 1. Fire alarm control panel.
 - 2. Annunciator panels.
 - 3. Remote power supplies for notification appliance circuits.
 - 4. Initiating devices (smoke detectors, heat detectors, manual pull stations, monitor modules, etc.)
 - 5. Relay modules to control protected premise fire safety functions.
 - 6. Notification appliances.
 - 7. Door hold-open devices.
 - 8. Tamper proof detector enclosures for detention cells.
- B. <u>Shop Drawings</u>: Prior to ordering or installing any equipment, contractor shall prepare shop drawings for submittal to Owner/Engineer. Shop drawings shall include sufficient information, clearly presented, to determine compliance with drawings and specifications. Include manufacturer's name(s), model numbers, ratings, power requirements, equipment layout, device arrangement, complete wiring point-to-point diagrams, and conduit layouts. Indicate type and gauge of wire to be used for each different circuit type. Show annunciator layout, configurations, and terminations.
- C. Submit four sets of drawings, descriptive data, battery calculations and voltage drop calculations to the Owner/Engineer for review. After review and acceptance by the Owner/Engineer, submit to State Fire Marshal for review. Any review comments, and associated drawing revisions, from state or local approving authorities that affect the system design shall be approved by the Owner/Engineer prior to installation.
- D. Testing Documentations/Certificates: Upon completion of installation and prior to final acceptance testing, complete and submit fire alarm system record of completion. Record of completion, along with all other material and test certificates shall be submitted to Project Engineer.
- E. As-Built Drawings: A complete set of "as-built" drawings showing installed wiring, color coding, and wire tag notations for exact locations of all installed equipment, specific interconnections between all equipment, and internal wiring of the equipment shall be delivered to the owner upon completion of system. As built drawings shall be furnished in printed (reproducible) format as well as electronic format.
- F. O&M Manuals: Operating and instruction manuals shall be submitted prior to testing of the system. Three (3) complete sets of operating and instruction manuals shall be delivered to the owner upon completion. User operating instructions shall be provided prominently displayed on a separate sheet located next to the control unit in accordance with U.L. Standard 864.
- G. Warrantee Letter: Provide letter stating that contractor will warrant all equipment and wiring to be free from inherent mechanical and electrical defects for one year (365 days) from the date of final acceptance. Provide information regarding any equipment warrantee provided by the equipment

manufacturer that exceeds 365 days.

1.05 SYSTEM DESCRIPTION:

- A. Remove existing fire alarm system including all control equipment, enclosures, power supplies, initiating circuits and devices, notification appliance circuits and devices and all wiring. Existing conduit and junction boxes may remain where they comply with the provisions of the specification and will be used to mount new devices.
- B. Furnish and install a new addressable FACP at location of existing FACP. FACP shall be Silent Knight model 5820XL or Fire-Lite MS-9600 with DACT-UD. FACP shall have integrated signaling line circuits (SLC) with sufficient capacity for all initiating devices and control modules required with an additional reserve of 20% unused addresses for future expansion.
- C. Furnish and install addressable initiating devices as indicated on the project drawings and as specified below:
 - 1. Smoke detectors: Provide smoke detectors in all corridors, lobbies, elevator shafts and elevator equipment rooms.
 - 2. Heat detectors: Provide fixed temperature type heat detectors in mechanical penthouse, elevator shafts and elevator equipment rooms.
 - 3. Duct smoke detectors: Provide duct mounted smoke detectors to detector smoke in both main air supply duct leaving air handler and for the common return air system. Provide a smoke detector for return air system on each level and at each opening or duct connecting to common return air shaft. Where air velocity is less than 300 FPS provide spot type smoke detector mounted in center of duct or return air opening. Where air velocity exceeds 3000 FPS provide detector mounted on exterior of duct with sampling tubes install within duct.
 - 3. Manual pull stations: Replace all existing manual pull stations with addressable devices. New pull stations may be mounted on existing junction boxes. Add new pull stations where indicated on plans
 - 4. Addressable monitor modules: Furnish and install modules to facilitate monitoring of existing fire sprinkler water flow and valve tamper switches.
- D. Provide addressable relay modules as indicated on the project drawings and specified below to provide the following protected premise fire safety functions:
 - 1. Secure door release
 - 2. Fan shutdown
 - 3. Door release
 - 4. Activation of NAC Circuits
 - 5. Elevator recall (primary and secondary)
 - 6. Elevator power shutdown
 - 7. Release exhaust vents at top of elevator shafts
 - 8. Interface with building security system
- E. Furnish and install notification appliances and remote power supplies for notification appliance circuits as indicated on the drawings.

1.06 <u>SYSTEM DESIGN</u>:

A. Basic Performance:

1. Alarm, trouble and supervisory signals from all intelligent reporting devices shall be encoded on NFPA Style 6 or 7 (Class A) Signaling Line Circuits (SLC).

- 2. Initiation Device Circuits (IDC) shall be wired Class A (NFPA Style D) as part of an addressable device connected by the SLC Circuit.
- 3. Notification Appliance Circuits (NAC) shall be wired Class A (NFPA Style Z).
- 4. All circuits shall be power-limited, per 1995 UL864 requirements.
- 5. A single ground fault or open circuit on the system Signaling Line Circuit shall not cause system malfunction, loss of operating power or the ability to report an alarm.
- 6. Alarm signals arriving at the main FACP shall not be lost following a primary power failure or outage of any kind until the alarm signal is processed and recorded.
- B. Basic System Functional Operation: When a fire alarm condition is detected and reported by one of the system initiating devices, the following functions shall immediately occur:
 - 1. The system Alarm LED on the FACP shall flash.
 - 2. A local sounder with the control panel shall sound.
 - 3. LCD display on the FACP and all remote annunciators shall indicate all information associated with the fire alarm condition, including the type of alarm point and its location within the protected premises.
 - 4. In response to a fire alarm condition, the system will process all control programming and activate all system outputs (alarm notification appliances and/or relays) associated with the point(s) in alarm.
 - 5. Alarm signal shall be transmitted off-premise via the DACT to the central monitoring station selected by the owner.
- C. All wiring shall be free of opens, shorts and grounds. All wiring shall be installed in rigid conduit or EMT. All penetrations through rated partitions shall be fire stopped with a suitable caulking compound. All wiring (except new power distribution circuits) shall be fire power limited (FPL) with minimum 300V insulation or equivalent complying with NFPA 70 Article 760.
- D. Provide a ground fault detection circuit, to detect positive and negative grounds on all field wiring. The ground fault detector shall operate the general trouble devices as specified but shall not cause an alarm to be sounded. Ground fault will not interfere with the normal operation, such as alarm, or other trouble conditions.
- E. All low voltage circuits will be protected by microprocessor controlled power limiting or have self restoring polyswitches for the following: smoke detector power, main power supply, indicating appliance circuits, battery standby power and auxiliary output.
- F. Notification circuits shall be designed to limit the voltage drop to a maximum of 20% from the power supply to the most remote device on any notification circuit.
- G. All visible alarms within a single field of view shall flash in synchronization.
- H. Secondary power supply (battery backup) shall be sufficient to provide a minimum of 24 hours of standby power with an additional reserve to operate the system for 5 minutes in alarm.

1.07 <u>WARRANTY</u>:

A. The contractor shall warrant all equipment and wiring free from inherent mechanical and electrical defects for one year (365 days) from the date of final acceptance.

1.08 <u>APPLICABLE CODES AND STANDARDS</u>:

A. The specifications and standards listed below form a part of this specification. The system shall

fully comply with all applicable provisions of the latest issue of these standards.

- 1. International Building Code 2003 edition
- 2. International Fire Code 2003 edition
- 3. International Mechanical Code 2003 edition
- 4. Utah State Fire Marshal Rule R710-4
- 5. NFPA 70 National Electrical Code 2002 edition
- 6. NFPA 72 National Fire Alarm Code 2002 edition
- 7. NFPA 90A Standard for the Installation of Air-Conditioning and Ventilating Systems 2002 edition
- 8. NFPA 101 Life Safety Code 2003 edition
- 9. ASME A17.1 2000 edition
- 10. DFCM standards/established procedures

PART II - PRODUCTS

2.01 GENERAL:

- A. All equipment and components shall be new, and the manufacturer's current model. The installer shall be an authorized representative of the manufacturer of the major equipment, such as control panels and shall be responsible for the satisfactory installation of the complete system.
- B. All equipment and components shall be installed in strict compliance with manufacturers' recommendations. Consult the manufacturer's installation manuals for all wiring diagrams, schematics, physical equipment sizes, etc., before beginning system installation.
- C. All equipment shall be attached to walls and ceiling/floor assemblies and shall be held firmly in place. Fasteners and supports shall be adequate to support the required load.

2.02 CONDUIT AND WIRE:

A. Conduit:

- 1. Conduit shall be in accordance with The National Electrical Code (NEC), local and DFCM requirements.
- 2. Conduit fill shall not exceed 40 percent of interior cross sectional area where three or more cables are contained within a single conduit.
- 3. Cable must be separated from any open conductors of Power, or Class 1 circuits, and shall not be placed in any conduit, junction box or raceway containing these conductors, as per NEC Article 760-29.
- 4. Wiring for 24 volt control, alarm notification, emergency communication and similar power-limited auxiliary functions may be run in the same conduit as initiating and signaling line circuits. All circuits shall be provided with transient suppression devices and the system shall be designed to permit simultaneous operation of all circuits without interference or loss of signals.
- 5. Conduit shall not enter the fire alarm control panel, or any other remotely mounted control panel equipment or backboxes, except where conduit entry is specified by the equipment manufacturer.
- 6. Conduit shall be 1/2 inch minimum.
- 7. Install conduit attached to structure by straps, staples, hangers or similar fittings designed and installed to support conduit. Installation shall conform to DFCM requirements, NFPA 70 Article 760 and 300.4.

- 8. Conduit shall be rigid or EMT. Flexible conduit may be used for a drop to a single device.
- 9. Conduit shall be concealed above ceilings or in walls where ceiling or walls are present. Conduit may be installed exposed in unfinished areas.
- 10. Conduit and junction boxes used for the fire alarm system shall be marked and labeled to indicate that they are part of the building fire alarm system. Conduits shall be periodically marked with red paint and labeled to indicate the circuit type and designation contained inside. Junction boxes shall be painted red.

B Wire:

- 1. All fire alarm system wiring must be new unless specified herein.
- 2. Wiring shall be in accordance with local, state and national codes (e.g., NEC Article 760) and as recommended by the manufacturer of the fire alarm system. Number and size of conductors shall be as recommended by the fire alarm system manufacturer, but not less than 16 AWG (1.02 mm) for initiating device circuits and signaling line circuits, and 12 or 14 AWG (1.63 mm) for notification appliance circuits.
- 3. All wire and cable shall be listed and/or approved by a recognized testing agency for use with a protective signaling system.
- 4. All wiring shall be installed inside permanent conduit or raceway or contained inside approved junction boxes or enclosures.
- 5. The system shall permit the use of IDC and NAC wiring in the same conduit or raceway with the multiplex communication loop.
- 6. All field wiring shall be completely supervised. In the event of a primary power failure, disconnected standby battery, removal of any internal modules, or any open circuits in the field wiring; a trouble signal will be activated until the system and its associated field wiring are restored to normal condition.
- 7. Terminal Boxes, Junction Boxes and Cabinets: All boxes and cabinets shall be UL listed for their use and purpose.
- 8. The fire alarm control panel and remote notification circuit power supplies shall be connected to dedicated branch circuits. Existing power circuit to FACP to be removed may be reused. Each circuit shall be labeled at the power distribution panel as FIRE ALARM. Primary power wiring shall be 12 AWG. Cabinets shall be grounded securely to either a cold water pipe or grounding rod.

2.03 FIRE ALARM CONTROL PANEL:

- A. FACP shall be either Silent Knight model 5820 XL or Fire-Lite MS-9600 with DACT-UD.
- B. Install all required expansion modules to ensure adequate SLC loop capacity for all initiating devices and control relays shown on panel with an additional reserve or a least 20% for future expansion.
- C. The FACP must have an integrated UL approved digital communicator. The communicator must allow local and remote up/downloading of system operating options, event history, and detector sensitivity data. The FACP must automatically test the smoke detectors in compliance with NFPA standards to ensure that they are within listed sensitivity parameters and be listed with Underwriters Laboratories for this purpose.
- D. The FACP must compensate for the accumulation of contaminants that affect detector sensitivity. Maintenance alert feature (differentiated from trouble condition), detector sensitivity selection, auto-programming mode (Jumpstart) and the ability to upgrade the core operating software on site or over the telephone.

- E. The main communication bus shall be capable of class A or class B configuration with a total Bus length of not less than 6,000 feet.
- F. The main control must have a built in annunciator with a minimum 80 character LCD display and feature LED's for General alarm, Supervisory, System trouble, System silence and Power. When in the normal condition the LCD shall display time and date which is capable of automatic daylight savings time adjustments. The annunciator must be able to silence and reset alarms through the use of a keypad-entered code, or by using a firefighter key. The annunciators must have twenty levels of user codes that will allow the limitation of operating system programming to authorized individuals.
- G. Provide all necessary system expansion modules required to provide a complete and functional fire alarm system as described on the project drawings and specified herein.

2.04 NOT USED:

2.05 ANNUNCIATOR PANELS:

A. The fire system shall be capable of supporting up to eight remote annunciators. LCD Remote annunciators shall have the same control and display layout so that they match identically the built in annunciator on the FACP. LED Remote annunciators shall have individually mapped LED's and reset and silence inputs. Remote annunciators shall be capable of operating at a distance of 6000 feet from the main control panel on unshielded non-twisted cable.

2.06 DACT:

A. The digital communicator shall be capable of reporting all zones or points of alarm, supervisory, and trouble as well as all system status information such as loss of AC, low battery, ground fault, loss of supervision to any remote devices with individual and distinct messages to a central station or remote station. The communicator must also be capable of up/downloading of all system programming options, Event history and Sensitivity compliance information to a PC on site or at a remote location. The communicator shall have an answering machine bypass feature that will allow the panel to respond to communication even on phone lines that have other communication equipment present. The communicator must be capable of reporting via SIA and Contact ID formats. The communicator shall have a delayed AC loss report function which will provide a programmable report delay plus a 10-25 min random component to help ease traffic to the central station during a power outage. DACT shall be integrated into the FACP circuitry or may be a separate card or panel connected to FACP and installed in FACP or adjacent enclosure.

2.07 SLC CIRCUITS:

A. Each SLC shall be capable of a wiring distance of 10,000 feet from the SLC driver module and be capable of supporting at least 127 devices per loop. The communication protocol to SLC devices must be digital. Any SLC loop device, which goes into alarm, must interrupt the polling cycle for priority response from the FACP. The FACP must respond consistently to a device that goes into alarm on an SLC in under 3 seconds. The SLC shall be capable of functioning in a class A configuration.

2.08 SLC LOOP DEVICES:

A. Devices supported must include analog photoelectric, ionization smoke detectors, analog heat detectors, manual pull stations, contact monitoring modules and relay output modules. There is to be no limit to the number of any particular device type that can be connected to the SLC.

2.09 <u>ADDRESSABLE SYSTEM DEVICES - GENERAL</u>:

- A. Addressable devices shall provide an address-setting means using rotary decimal switches.
 - 1. Addressable devices shall use simple to install and maintain address switches.
 - 2. Detectors shall be Analog and Addressable, and shall connect to the fire alarm control panel's Signaling Line Circuits.
 - 3. Addressable smoke and thermal detectors shall provide dual (2)status LEDs. Both LEDs shall flash under normal conditions, indicating that the detector is operational and in regular communication with the control panel, and both LEDs shall be placed into steady illumination by the control panel, indicating that an alarm condition has been detected.
 - 4. Using software in the FACP, detectors shall automatically compensate for dust accumulation and other slow environmental changes that may affect their performance. The detectors shall be listed by UL as meeting the calibrated sensitivity test requirements of NFPA Standard 72, Chapter 7.
 - 5. The detectors shall be ceiling-mount and shall include a separate twist-lock base which includes a tamper proof feature.
 - 6. The detectors shall provide a test means whereby they will simulate an alarm condition and report that condition to the control panel.
 - 7. Detectors shall also store an internal identifying type code that the control panel shall use to identify the type of device (ION, PHOTO, THERMAL).

2.10 <u>INTELLIGENT PHOTOELECTRIC SMOKE DETECTOR:</u>

A. The detectors shall use the photoelectric (light-scattering) principal to measure smoke density and shall, on command from the control panel, send data to the panel representing the analog level of smoke density.

2.11 <u>INTELLIGENT THERMAL DETECTORS</u>:

A. Thermal detectors shall be intelligent addressable devices rated at 135 degrees Fahrenheit (58 degrees Celsius) fixed temperature element. Detectors incorporating a rate of rise mechanism shall not be used. Detector shall mount to a base that is connected to the fire alarm control panel signaling line circuit.

2.12 INTELLIGENT DUCT SMOKE DETECTOR:

- A. The in-duct smoke detector housing shall accommodate an intelligent photoelectric detector that provides continuous analog monitoring and alarm verification from the panel.
- B. When sufficient smoke is sensed, an alarm signal is initiated at the FACP, and appropriate action taken to shutdown air handling systems to help prevent the rapid distribution of toxic smoke and fire gases throughout the areas served by the duct system.

2.13 <u>ADDRESSABLE DRY CONTACT MONITOR MODULE</u>:

- A. Addressable monitor modules shall be provided to connect one supervised IDC zone of conventional alarm initiating devices (any N.O. dry contact device) to one of the fire alarm control panel SLC loops.
- B. The monitor module shall mount in a 4-inch square, 2-1/8 inch deep electrical box.

C. The IDC zone shall be suitable for Class A Style D operation. An externally visible LED shall be provided that shall flash under normal conditions, indicating that the monitor module is operational and in regular communication with the control panel. LED shall illuminate continuously when monitored device is in alarm state.

2.14 ADDRESSABLE CONTROL MODULE:

- A. Addressable control modules shall be provided to supervise and control the operation of one conventional NACs of compatible, 24 VDC powered, polarized audio/visual notification appliances. For fan shutdown and other auxiliary control functions, the control module may be set to operate as a dry contract relay.
- B. The control module shall mount in a standard 4-inch square, 2-1/8 inch deep electrical box, or to a surface mounted backbox.
- C. The control module NAC may be wired for Style Z (Class A) with up to 1 amp of inductive A/V signal, or 2 amps of resistive A/V signal operation, or as a dry contact (Form-C) relay. The relay coil shall be magnetically latched to reduce wiring connection requirements, and to insure that 100% of all auxiliary relay or NACs may be energized at the same time on the same pair of wires.
- D. Audio/visual power shall be provided by a separate supervised power loop from the main fire alarm control panel or from a supervised, UL listed remote power supply.
- E. The control module shall be suitable for pilot duty applications and rated for a minimum of 0.6 amps at 30 VDC.

2.15 MANUAL PULL STATIONS:

A. Manual Fire Alarm Stations shall be non-coded, double action type, with a key operated test reset lock in order that they may be tested, and so designed that after actual emergency operation, they cannot be restored to normal except by use of a key. The reset key shall be so designed that it will reset the manual Pull Station and open the FACP cabinet without use of another key. An operated station shall automatically condition itself so as to visually detected, as operated, at a minimum distance of fifty feet, front or side. Manual stations shall be constructed of die cast metal with clearly visible operating instructions on the front of the station in raised letters. Stations shall be suitable for surface mounting on matching back box, or semi-flush mounting on a standard single gang box, and shall be installed within the limits defined by the Americans with Disabilities Act (ADA) dependent on Manual Station accessibility or per local requirements.

2.16 <u>BATTERIES AND EXTERNAL CHARGER</u>:

A. Battery:

- 1. Shall be 12 volt, Gell-Cell type.
- 2. Battery shall have sufficient capacity to power the fire alarm system for not less than 24 hours plus 5 minutes of alarm upon a normal AC power failure.
- 3. The batteries are to be completely maintenance free. No liquids are required. Fluid level checks refilling, spills and leakage shall not be required.

B. External Battery Charger:

- 1. Shall be completely automatic, with constant potential charger maintaining the battery fully charged under all service conditions. Charger shall operate from a 120-volt 60 hertz source.
- 2. Shall be rated for fully charging a completely discharged battery within 48 hours while simultaneously supplying any loads connected to the battery.
- 3. Shall have protection to prevent discharge through the charger.
- 4. Shall have protection for overloads and short circuits on both AC and DC sides.

2.17 ENCLOSURES:

- A. The control panels shall be housed in a UL listed cabinet suitable for surface or semi-flush mounting. Cabinet and front shall be corrosion protected, given a rust-resistant prime coat, and manufacturer's standard finish.
- B. The back box and door shall be constructed of 0.060 steel with provisions for electrical conduit connections into the sides and top.
- C. The door shall provide a key lock and shall include a glass or other transparent opening for viewing of all indicators.
- D. The control unit shall be modular in structure for ease of installation, maintenance, and future expansion.

2.18 NOTIFICATION APPLIANCES:

- A. The visible and audible/visible signals shall be listed by Underwriters Laboratories Inc. per UL 1971 and/or 1638.
- B. Each indicating appliance circuit shall be electrically supervised for opens, grounds and short circuit faults, on the circuit wiring, and shall be so arranged that a fault condition on any indicating appliance circuit or group of circuits will not cause an alarm to sound. The occurrence of any fault will light the trouble LED and sound the system trouble sounder, but will not interfere with the proper operation of any circuit which does not have a fault condition.
- C. The notification appliance (combination audible/visible units only) shall produce a peak sound output of 90dba or greater as measured in an anechoic chamber. The visible signaling appliance shall maintain a minimum flash rate of 1Hz or greater regardless or power input voltage. The appliance shall also be capable of meeting the candela requirements of the blueprints presented by the Engineer and ADA. The appliance shall be capable of synchronization with all other appliances in the same filed of view.
- D. The appliance shall be polarized to allow for electrical supervision of the system wiring.
- E. The unit shall be provided with terminals with barriers for input/output wiring and be able to mount a single gang or double gang box or double workbox with the use of an adapter plate.
- F. The unit shall have an input voltage range of 20-30 volts with either direct current or full wave rectified power.

2.19 SPARE DEVICES:

A. Furnish the owner with a stock of spare initiating devices and notification appliances to allow for future addition/relocation of devices or replacement of equipment that fails after expiration of the warrantee period. Manufacturer and model number of spare devices shall match those of devices

used for the system installation. Minimum number and type of devices per building shall be as indicated below:

- 1. Two addressable heat detectors.
- 2. Six addressable smoke detectors.
- 3. Two addressable manual pull stations.
- 4. One addressable contact monitor module.
- 5. Two addressable control modules.
- 6. Eight notification appliances corresponding to the type and proportion of notification appliances installed.

PART III - EXECUTION

3.01 INSPECTION:

- A. Contractor shall be responsible to attend a mandatory pre-bid walk through of the building. If required, an additional pre-bid inspection can be arranged. The contractor shall be responsible to examine all areas and conditions under which fire alarm systems are to be installed and identify conditions detrimental to proper completion of the work. All unsatisfactory conditions shall be specifically identified in the bid.
- B. Extent and location of existing fire alarm equipment shown on bid drawings is based on informal field surveys of each building and should be considered to be approximate. Contractor shall be responsible to conduct a detailed inspection to verify conditions prior to designing the new fire alarm systems.

3.02 <u>INSTALLATION</u>:

- A. Installation shall be in accordance with the NEC, NFPA 72, local and state codes, as shown on the drawings, and as recommended by the major equipment manufacturer.
- B. All conduit, junction boxes, conduit supports and hangers shall be concealed in finished areas and may be exposed in unfinished areas. Smoke detectors shall not be installed prior to the system programming and test period.
- C. All fire detection and alarm system devices, control panels and remote annunciators (unless otherwise noted on drawings) shall be flush mounted when located in finished areas and may be surface mounted when located in unfinished areas.
- D. Contractor is responsible for making his own job check and any necessary adjustments in the design prior to installation. Make final coordination with existing building elements and adjust design as necessary. Major conflicts shall be brought to the attention of the Project Engineer for resolution.
- E. Work shall be performed in a manner to minimize interruptions in service of the existing fire alarm system. Contractor shall be responsible to provide a fire watch throughout all times that the automatic fire alarm and detection service is interrupted. Off-premise monitoring of the fire sprinkler control valves and water flow switches shall be provided at all times.
- F. Existing conduit and junction boxes not used for the new fire alarm system may remain. Contractor shall remove all existing wiring from abandoned conduits and junction boxes. Abandoned junction boxes in finished areas shall be covered with a decorative plate (to be approved by the owner).

- G. Work only in one area of a building at a time. Complete all required work in that area before proceeding to the next area.
- H. Contractor shall prepare a schedule of work to be performed and submit the schedule to the building coordinator for review/approval.
- I. Work during normal business hours will be allowed but must be scheduled in advance with building coordinator. Operations involving the creation of dust, debris or distracting noise shall be scheduled in advance with the building coordinator and shall be performed early in the morning or near the end of the work day.

3.03 FIELD QUALITY CONTROL:

- A. Obtain permits and post bonds as required by state and local AHJ's (Authorities Having Jurisdiction).
- B. Inform AHJ's of job progress. Request presence of AHJ's, perform tests, and document results using Contractor's Material and Test Certificates.

3.04 <u>TESTING/TRAINING</u>:

- A. Make and pay for all tests required by applicable codes during and after completion of the work and correct and defects in the systems indicated by the tests.
- B. The service of a competent, factory-trained engineer or technician authorized by the manufacturer of the fire alarm equipment shall be provided to technically supervise and participate during all of the adjustments and tests for the system.
- C. Testing shall include but not be limited to the following:
 - 1. Before energizing the cables and wires, check for correct connections and test for short circuits, ground faults, continuity, and insulation.
 - 2. Open initiating device circuits and verify that the trouble signal actuates.
 - 3. Open signaling line circuits and verify that the trouble signal actuates.
 - 4. Open and short notification appliance circuits and verify that trouble signal actuates.
 - 5. Ground initiating device circuits and verify response of trouble signals.
 - 6. Ground signaling line circuits and verify response of trouble signals.
 - 7. Ground notification appliance circuits and verify response of trouble signals.
 - 8. Check alert tone and prerecorded voice message to all alarm notification devices.
 - 9. Check installation, supervision, and operation of all intelligent smoke detectors using walk test.
 - 10. Each of the alarm conditions that the system is required to detect should be introduced on the system. Verify the proper receipt and the proper processing of the signal at the FACP and the correct activation of the control points.
 - 11. Test system batteries to verify that secondary power supply is sufficient to provide specified standby and alarm power.
- D. Train the Owner's maintenance personnel in the proper operation, testing and maintenance of all installed equipment. Training shall be sufficient to enable owner to service equipment, add or remove devices and make programming changes.

3.05 FINAL INSPECTION:

A. At the final inspection, a factory-trained representative of the manufacturer of the major equipment shall demonstrate that the system functions properly in every respect.

3.06 <u>INSTRUCTION</u>:

- A. Instruction shall be required for operating the system. Hands-on demonstrations of the operation of all system components and the entire system including program changes and functions shall be provided.
 - B. The contractor and/or the systems manufacturer's representatives shall provide a typewritten "Sequence of Operation

3.07 CLEANING:

- A. Remove dust, scale, debris, and foreign substances from interior and exterior of devices, equipment, and materials prior to installation.
- B. Upon job completion, remove tools, surplus materials and equipment, leaving all areas broom clean.

3.07 <u>AUTHORITIES HAVING JURISDICTION:</u>

- A. Acceptance of installation is subject to final inspection and approval by:
 - 1. State of Utah Fire Marshal's Office
 - 2. State of Utah Division of Facilities and Construction Management
 - 3. Building Maintenance Personnel
 - 5. Project Engineer.

END OF SECTION 13851